



Classified by
Underwriters Laboratories, Inc.
to UL 1479

System No. C-AJ-2567

F Rating — 2 Hr


T Ratings — 0, 1-1/4 and 2 Hr (See Item 2)

L Rating At Ambient — Less Than 1 CFM/sq ft

L Rating At 400 F — 4 CFM/sq ft

W Rating — Class 1 (See Item 4C)

CAJ 2567



1. Floor or Wall Assembly — Min 4-1/2 in. (114 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) concrete floor or min 5 in. (127 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) concrete wall . Wall may also be constructed of any UL Classified Concrete Blocks*. Floor may also be constructed of any 6 in. thick UL Classified hollow core Precast Concrete Units. Max diam of opening is 4 in. (102 mm).

See Concrete Blocks (CAZT) and Precast Concrete Units* (CFTV) categories in the Fire Resistance Directory for names of manufacturers.

2. Steel Sleeve — (Optional) — Nom 4 in. (102 mm) diam (or smaller) Schedule 40 (or heavier) steel pipe cast or grouted into floor or wall assembly, flush with floor or wall surfaces or extend a max 3 in. (76 mm) above the floor or beyond both surfaces of the wall. The T Rating for the firestop system is 2 hr except that when the steel sleeve is provided. If the steel sleeve is installed flush with both surfaces of the floor or wall, the T Rating of the firestop system is 1-1/4 hr. If the steel sleeve extends beyond the top surface of the floor or both surfaces of the wall, the T Rating of the firestop system is 0 hr.



Hilti Firestop Systems

Reproduced by HILTI, Inc. Courtesy of
Underwriters Laboratories, Inc.
November 15, 2021

3. Through Penetrants — One nonmetallic pipe to be installed either concentrically or eccentrically within the firestop system. The annular space between pipe and sleeve (Item 2) shall be min 1/4 in. (6 mm) to max 1-3/8 in. (35 mm). When steel sleeve (Item 2) is not provided, the annular space between pipe and periphery of opening shall be min 0 in. (point contact) to max 1-5/8 in. (41 mm). Pipe to be rigidly supported on both sides of floor or wall assembly. The following types and sizes of nonmetallic pipes may be used:
- A. Polyvinyl Chloride (PVC) Pipe — Nom. 2 in. (51 mm) diam (or smaller) Schedule 40 solid-core or cellular core PVC pipe for use in closed (process or supply) or vented (drain, waste or vent) piping system.
 - B. Chlorinated Polyvinyl Chloride (CPVC) Pipe — Nom 2 in. (51 mm) diam (or smaller) SDR17 CPVC pipe for use in closed (process or supply) or vented (drain, waste or vent) piping systems.
 - C. Rigid Nonmetallic Conduit+ — Nom 2 in. (51 mm) diam (or smaller) Schedule 40 PVC conduit installed in accordance with Article 347 of the National Electrical Code (NFPA 70).
 - D. Crosslinked Polyethylene (PEX) Tubing — Nom 2 in. (51 mm) diam (or smaller) SDR 9 PEX tubing for use in closed (process or supply) piping systems.
 - E. Polypropylene (PP-R) Pipe — Nom 2 in. (63 mm OD) (or smaller) Aquatherm Greenpipe SDR 7.4 or 11 for use in closed (process or supply) piping systems.
 - F. Polypropylene (PP-RCT) Pipe — Nom 2 in. (63 mm OD) (or smaller) Aquatherm Bluepipe SDR 9, 11 or 17.6 for use in closed (process or supply) piping systems.
 - G. Polypropylene (PP-RCT) Pipe — Nom 2 in. (63 mm OD) (or smaller) Nupi Americas Niron pipe SDR 7.3, 11 or 17 for use in closed (process or supply) piping systems.
 - H. Polypropylene (PP-RCT) Pipe — Nom 2 in. (63 mm OD) (or smaller) Aquatechnik NA Fusion-Tech pipe SDR 7.4, 11 or 17.6 for use in closed (process or supply) piping systems.
 - I. Polypropylene (PP) Pipe — Nom 2 in. (63 mm OD) (or smaller) Uponor pipe SDR 9 or 11 for use in closed (process or supply) piping systems.
4. Firestop System — The firestop system shall consist of the following:
- A. Packing Material — Min 4 in. (102 mm) thickness of min 4 pcf (64 kg/m³) mineral wool batt insulation firmly packed into opening as a permanent form. Packing material to be recessed from top surface of floor or both surfaces of wall to accommodate the required thickness of fill material. When precast concrete units are used, packing material to be recessed from top surface of floor to accommodate the required thickness of fill material and to be installed flush with bottom surface of floor.
 - B. Fill, Void or Cavity Material* — Sealant — Min 1/2 in. (13 mm) thickness of fill material applied within the annulus, flush with top surface of floor or both surfaces of wall assembly. Additionally, nom 1/2 in. (13 mm) bead of fill material applied between concrete and penetrant interface. When W Rating is required, the 1/2 in. (13 mm) depth of fill material shall be recessed min 1/4 in. (6 mm) below top surface of floor to accommodate additional sealant (Item 4C).
HILTI CONSTRUCTION CHEMICALS, DIV OF HILTI INC — FS-ONE MAX Intumescent Sealant
 - C. Fill, Void or Cavity Material* — Sealant — (Optional, Not Shown) — When min annular space is 3/16 in. (4.8 mm) and when the FS-One Sealant (Item 4B) is recessed 1/4 in. (6 mm) from the top surface of the floor, flush with top surface of floor, to attain the W Rating. W Rating applies only when CFS-S SIL GG or CFS-S SIL SL (floors only) Sealant is used.
HILTI CONSTRUCTION CHEMICALS, DIV OF HILTI INC — CFS-S SIL GG or CFS-S SIL SL (floors only) Sealant

* Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.

